

AGGREGATE FACILITY CAPACITY - Gallons		0 to ≤ 660	>660 to < 25K	≥ 25K to < 1MM	≥ 1MM
AST REQUIREMENT	Regulatory Reference 9VAC25-91				
Excluded from Regulation	30.A.3	X			
Registration of Tank(s) w/DEQ	100.A		X	X	X
Re-registration every 5 years	100.F		X	X	X
Registration of Tank(s) w/Local Officials	100.G		X	X	X
Closure Assessment	120		X	X	X
Record-keeping	150			X	X
Inventory Control Testing	130.B.1			X	X
Secondary Containment	130.B.2			X	X
Safe Fill & Shutdown	130.B.3			X	X
Pressure Testing of Pipes	130.B.4			X	X
Visual Daily & Weekly Inspection of Tanks	130.B.5			X	X
Training of Individuals	130.B.6			X	X
Leak Detection	130.B.7			X	X
Formal Inspection (new tanks)	130.C.1				X
Formal Re-inspection	130.C.2				X
Safe Fill & Shutdown & High Level Alarm	130.C.3				X
Cathodic Protection of Piping	130.C.4				X
Performance Standards for ASTs Newly Installed, Retrofitted, or Brought Into Use	140			X	X
Oil Discharge Contingency Plan (22 items)	170			X	X
Groundwater Characterization & Monitoring	180 & 190				X